

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**



**LISTING No.** 7165-1703:125

Page 1 of 2

**CATEGORY:** Control Unit (Non High-Rise)

**LISTEE:** Gamewell-FCI, 12 Clintonville Road, Northford CT 06472  
Contact: Brian Carlson (781) 471-3000 Fax (781) 471-3099  
*Brian.carlson@honeywell.com*

**DESIGN:** Model E3 BROADBAND and E3 CLASSIC Voice Evacuation System. The E3 Systems may also work in conjunction with all the sub-assemblies of listee's 7100 Series Control Panel and NetSOLO systems (\*CSFM Listing No. 7170-1703:117, 7165-1703:105 and 6911-1703:116, 6911-1703:118).

Unit conveys all fire alarm, audio evacuation, voice paging, and fire fighter communications. Power-limited; non-coded, automatic, manual, smoke control, water flow, sprinkler supervisory, local auxiliary, central station, remote station, and proprietary service. Refer to listee's data sheet for additional detailed product description and operational considerations.

System components:

ILI-MB-E3	Intelligent Loop Interface Master Board
PM-9	Power Supply
*ILI-95-MB-E3, *ILI-95-S-E3	Loop Interface Subassemblies
RPT-E3-FO or	Repeater Sub-assembly, Fiber Optic or
RPT-E3-UTP	Repeater Sub-assembly, Unshielded twisted pair wire
LCD-E3	LCD Keypad Display
DACT-E3 sub-assembly	Digital alarm communicator transmitter
ILI-S-E3	Intelligent Loop Unit, Expansion Board Enclosure
ASM-16	Addressable switch module
or	
7100 Series#	Fire Alarm Control Panel
INI-7100 UTP#	Intelligent Network Interface Sub-assembly, [Twisted, unshielded wire] or
INI-7100 FO#	Intelligent Network Interface

**RATING:** 120 V, 60 Hz, 3.5 A Primary; 24 V dc, 9A Secondary

**INSTALLATION:** In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model designation, electrical rating and UL label.

**APPROVAL:** Listed as non high-rise fire alarm control unit for use with separately listed electrically and functionally compatible initiating and indicating devices.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NPFA 72, 2002 Edition.

This control unit meets the requirements of UL Standard 864, \*9<sup>th</sup> Edition.

**NOTE:** For **Fire Alarm Verification Feature** (delay of alarm signaling), the Retard/Reset/Restart period shall be 30 seconds or less.

**FORMERLY:** 7165-0694:268

\*Rev. 09-08-08 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **SEPTEMBER 9, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**  
*Fire Engineering Division*